

Photoelectric Sensors DPB



User Manual

 $Thank you for choosing \ Degson products. \ Please read this instruction manual carefully before using the product.$

- It is intended to be used by personnel with certain electrical knowledge.
- Before using this product, please read this manual carefully and use it correctly after fully understanding the product.
- For your convenience, please keep this manual properly so that you can refer to it at any time.

symbol

The following symbols are important reminders in this manual. Please be sure to comply with the following.



There is a risk of malfunction or fire. Please do not exceed the rated voltage when using.



Do not use AC power as there is a risk of rupture.



There is a risk of burns due to high temperatures.

Safety Tips

To ensure your safety, please be sure to follow the following.

- Do not use in an environment with flammable or explosive gases.
- Do not use the product in an environment with water, oil, chemical droplets, or in contact with steam.
- Do not disassemble, repair, or modify the product without authorization.
- Do not exceed the rated voltage and current range during use.
- Do not use in environments beyond the rated value.
- Please pay attention to the polarity of the working power supply and do not connect the wrong wires.
- Please connect the load correctly.
- Do not short-circuit the load
- Do not use if the casing is damaged.
- When disposing of it, please treat it as industrial waste.
- Do not use in direct sunlight.
- Due to the use conditions (ambient temperature, power supply voltage, etc.),

the sensor surface temperature may rise. Please be careful when operating or cleaning it, as there is a risk of burns.

Instructions for use

- Do not use in the following places:
- Locations exposed to direct sunlight
- Places with high humidity and easy condensation
- Places containing corrosive gases
- Locations where vibration and shock are directly transmitted to the product body
- When the lead wires of this product are installed in the same conduit as the power wires and electric power wires, hey may be interfered with, malfunction or even be damaged.
- Extension cables must have a cross-sectional area of 0.3mm² or more and a length of 100m or less. When using Korean S-mark certified models as certified products, please set the length to 10m or less.
- The forces applied to the conductors are as follows: tension less than 40 N, torque less than 0.1 N-m, pressure less than 20 N, bending less than 3 kg.
- After the power is turned on, the product is in a detectable state within 200ms. Therefore, if the load and the product are
 connected to different power supplies, the power of the product must be turned on first.
- After cutting off the power supply, output pulses may occur, so please cut off the power supply of the load or load line first.
- Please do not use solvents such as thinner, gasoline, acetone, kerosene, etc. to clean.

Confirmation of packaging contents


- sensor
- User Manual one

Technical specifications

type	DPB Series
model	DPB-B30N(P)-B
Detection method	Diffuse reflection-background suppression
Detection distance	White paper: 2 ~300mm
Set distance	30∼300mm adjustable
Spot diameter	Ф 16mm (at 300mm)
Hysteresis range	<5%
Output Mode	NPN/PNP open collector
Output Mode	NPN/PNP open collector
Switch mode	L.on (light-incoming action) / D.on (light-blocking action) switchable
Indicator Lights	Working indicator light: green; output indicator light: red
Response time	≤1.5ms
Sensitivity adjustment	6-turn potentiometer
lightsource	Blue LED465nm (modulated)
Supply voltage	10~30V DC
Current consumption	≤20mA
Load current	≤100mA
Residual voltage	<1.5V (load current ≤ 100mA)
Protection Circuit	Power reverse polarity protection, surge protection, short circuit protection
Insulation withstand voltage	Insulation: ≥50MΩ (500VDC);Withstand voltage: ≤0.1mA (1000VAC)
Impactresistance	50G (500m/s²)
Vibration resistance	10~55Hz sweep frequency, 1.5mm amplitude, 2 hours each in X, Y, and Z directions
Ambientillumination	Sunlight ≤ 10,000 lux; Incandescent lamp ≤ 3,000 lux
Operating temperature	Working temperature: -25°C-+55°C, no freezing; storage temperature: -30°C−+70°C
Ambient humidity	Working: 35%-85%RH,no condensation, Storage: 35%-95%RH
Protection level	IP67
Outlet mode	2M/4 core cable 4mm diameter
Material	PBT+glassfiber (shell); PMMA (lens)
Accessories	screwdriver
	I .

Circuit Diagram

DPB-B30N(P)-B



brown ①

10-30V DC

black ④

Switching output

White ②

Floating Light on


blue 3

0V Dark.on

Dimensions

PNP output

DPB-B30N(P)-B



Power Distribution Considerations

Supply voltage


Do not use the product beyond the voltage range. Inputting voltage beyond the range or inputting AC power into a DC power type and the product beyond the voltage range. The product beyond the voltage range is a power type and the product beyond the voltage range. The product beyond the voltage range is a power type and the product beyond the voltage range. The product beyond the voltage range is a power type and the voltage range is a power type and the voltage range. The product beyond the voltage range is a power type and the voltage range. The voltage range is a power type and the voltage range is a power type and the voltage range is a power type and the voltage range. The voltage range is a power type and the voltage range range is a power type and the voltage range is a power type and the voltage range is a power type range is a power type range ismay cause the product to rupture or burn out.



Load short circuit


Do not short-circuit the load to avoid rupture or burning.

The load short-circuit holding function is a function used within the rated voltage with the correct polarity of the power supply.



Miswiring

Do not mismatch the polarity of the power supply, as this may cause rupture or burning.



When no load is connected

If the power supply is directly connected to the internal element without load, it may cause cracking or burning. Therefore, please add load before wiring.



Regular maintenance checks

During the use period, regular inspection and maintenance are very necessary to ensure the normal operation of the machine. The regular inspection items are as follows:

- When detecting an object, whether the switch is within the distance, whether it is loose, whether it is tilted, and whether the detected object has changed.
- Whether the wiring or connecting wires are in normal contact or there is no concern about disc.
- Whether there is dust on the sensing surface.
- · Check whether the operating temperature and surrounding environment are normal.
- Check the installation space for any abnormalities, such as vibration, electrical leakage, etc.

After power is turned on, the sensor needs a lead time of 100ms to achieve stable output of the sensor. Therefore, do not operate the sensor during this period. Avoid using it outdoors (except when there is a shield).

- Avoid direct contact with organic solvents
- Avoid objects hitting the detection surface, as the sensing surface is very fragile.
- Do not pull or move the power supply excessively during installation or movement.















Precautions

- Please make sure that the power is off when wiring.
- Please confirm that the power supply voltage varies within the rated range.
- If the power is provided by a commercial switching regulator, make sure that the frame ground terminal (FG) of the power supply is connected to ground.
- Be sure to connect the equipment ground terminal (FG) to ground.
- Do not use the device within a short period of time (0.5s) after the power is turned on.
- Do not run the wiring together with high voltage or power lines or in the same conduit as this may cause malfunction due to induction.
- Avoid dust,dirt and water vapor
- . Do not put the sensor in direct contact with water, oil, grease or organic solvents such as thinners.

Product Commitment

Degson's products undergo strict factory inspection. If a fault occurs, please contact the nearest Degson office and provide detailed information so that we can solve it as soon as possible.

Warranty

• The product warranty period is one year, starting from the date the product is shipped to the place designated by the purchaser.

Warranty coverage

(1) If a fault occurs during the warranty period stated above and caused by Degson, Degson will repair the product free of charge. However, the following situations are not covered by the warranty.

- Failure to comply with the conditions and environment specified in the operating instructions, user manual or technical requirements specifically agreed upon between the purchaser and Degson Faults caused by incorrect operation or improper use.
- The failure is not due to a product defect but is caused by the design of the purchaser's equipment or software.
- The failure is caused by modification or repair performed by someone other than Degson
- Failures that can be completely avoided by properly repairing or replacing wearing parts in accordance with the operating instructions or user manual.
- Failures caused by unforeseen changes in the level of science and technology after the product is shipped from Degson.
- Failures caused by natural disasters such as fire, earthquake and flood, or external factors such as abnormal voltage are not covered by Degson.

2)The warranty coversonly the situations specified in Article(1). Degson shall not be liable for any indirect losses(damage to equipment, loss of opportunity, loss of profits, etc.) or other losses caused to the purchaser by its equipment.

Product Suitability

Degson's products are designed and manufactured as general-purpose products for general industries. Therefore, Degson's products must not be used for the following applications and are not suitable for their use. However, if the purchaser consults Degson in advance about the use of the product with a responsible attitude and understands the technical specifications, grades and performance of the product, and takes necessary safety measures, the product can be used. In this case, the product warranty scope is the same as above.

- Uses that may result in chemical contamination or electrical interference, or use under conditions or environments not described in the product catalog instruction manual, etc.
- Atomic energy control equipment, incineration equipment, railway, aviation, vehicle equipment, safety devices, and administrative agencies and equipment manufactured in accordance with the regulations of individual industries.
- Machinery, systems and devices that may endanger life or property.
- Gas, water, and electricity supply systems require highly reliable equipment that operates continuously 24 hours a day.